

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Job #16-77-B-35-10-32

County Thomas		Fraction SW 1/4 NE 1/4 NW 1/4	Section number 35	Township number T 10 S	Range number R 32 E/W
2. Distance and direction from nearest town or city: From Oakley; 3/4 North; 1/4 East Street address of well location if in city:			3. Owner of well: Meeds Redi-Mix - Dave Meeds R.R. or street: City, state, zip code: Oakley, Kansas		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 30 in. Completion date 3-2-77 Well depth 155 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
9. Casing: Material Steel Height: Above xxxx Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight .188 lbs./ft. Dia. 16 in. to 65 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7			10. Screen: Manufacturer's name Brown Type Regular Dia. 16" Slot/gauze 10% Length 80' Set between 65 ft. and 145 ft. 10' Cook 145 ft. and 155 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 30# 1/2		
			11. Static water level: 46 ft. below land surface Date 3-10-77 12. Pumping level below land surfaces: 145 ft. after 2 hrs. pumping 1084 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1084 g.p.m.		
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 3-10-77			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> Clay With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> xxxx Concrete Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: 1300 ft. Direction N Type Farmstead Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			17. Pump: Manufacturer's name Floway Model number 85143 HP 40 Volts <input type="checkbox"/> Length of drop pipe 149 ft. capacity 700 g.p.m. Type: 4 Stage 10 DOH <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address Box 852 Colby, KS 67701 Signed Sally Barry Date 4/27/77 Authorized representative		
18. Elevation:			19. Remarks:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5