


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Thomas		Fraction NW 1/4 NW 1/4 NE 1/4		Section number 36		Township number T 10 S		Range number R 33 E/W					
1. Location of well: 4 west 1 north of Oakley				2. Distance and direction from nearest town or city: 4 west 1 north of Oakley									
Street address of well location if in city:				3. Owner of well: Dean Bell R.R. or street: Rm2 Box 142 City, state, zip code: Oakley, Kansas 67748									
4. Locate with "X" in section below: 				Sketch map:		6. Bore hole dia. 8 in. Completion date 9/9/77 Well depth 171 ft.							
5. Type and color of material				From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
Top Soil				0		37		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
Sand and clay Strips				37		72		9. Casing: Material plst Height: Above or below Threaded <input type="checkbox"/> Welded gl Surface 20 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 171 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1/4"					
Sand clay				72		80		10. Screen: Manufacturer's name J and L Type RMP Dia. 5" Slot/gauze .032 Length 20' Set between 151 ft. and 171 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/8"					
Sand and sand rock Strips				80		113		11. Static water level: <input type="checkbox"/> mo./day/yr. 110 ft. below land surface Date 9/9/77					
Sand and clay				113		127		12. Pumping level below land surfaces: <input type="checkbox"/> ft. after NA hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.					
Sand and sand rock Strips				127		129		13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>					
Sand clay				129		136		14. Well head completion: yes yes less adapter 20 inches above grade					
sand				136		139		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 16 ft.					
Sand and clay				139		155		16. Nearest source of possible contamination: ft. <input type="checkbox"/> NA action <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Sand				155		157		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
Sand clay				157		166		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bartell Drilling 139 Business name winona, Kansas 67764 License No. 10-7-78 Address Joyce Bartell Signed Joyce Bartell Date 10-7-78 Authorized representative					
Oker and Shale				166		171							
BROCK 166'													
(Use a second sheet if needed)													
18. Elevation:		19. Remarks:											
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Pump was not installed by us.											

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5