


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

Mc ALLASTON NW

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

CAA

1. Location of well:		County SHERMAN	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 4	Township number T 10 S	Range number R 37 E	
2. Distance and direction from nearest town or city: Edson Street address of well location if in city: HE 7 1/2 S 1/2 E			3. Owner of well: IRON Mueller R.R. or street: City, state, zip code: BIRD CITY KANSAS 67731				
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			6. Bore hole dia. 8 in. Completion date _____ Well depth 145 ft. 8-2-76	
5. Type and color of material			From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
M Gravel			146	153	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay M Gravel			153	157	9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 153 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200 237		
Ochac			157	165	10. Screen: Manufacturer's name Jess Lowell Type Layer Dia. 5 Slot/gauze 1/8 - 20 Length 12 Set between 153 ft. and 165 ft. ft. and _____ ft. Gravel pack? YES Size range of material 1/8		
Top Soil			0	3	11. Static water level: _____ mo./day/yr. 150 ft. below land surface Date 8-2-76		
Clay, Fine Sand			3	71	12. Pumping level below land surfaces: 160 ft. after 3 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.		
Gravel Clay			71	96	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Fine Sand, Sandy Clay			96	146	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
MAC					15. Well grouted? YES With: <input checked="" type="checkbox"/> Mortar <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
BROCK ?					16. Nearest source of possible contamination: PASTURE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)							
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 3496		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. S & H Drilling Co. Inc. 146 Business name _____ License No. _____ Address Goodland Kansas Signed Bill Clapper Date 8-10-76 Authorized Representative			

T 10 R 37 E S 4 NE 1/4 SW 1/4