

1 LOCATION OF WATER WELL: County: OTTAWA	Fraction SE 1/4 NE 1/4 SE 1/4	Section Number 36	Township Number T 10 S	Range Number R 4W E/W
--	---	-----------------------------	----------------------------------	---------------------------------

Distance and direction from nearest town or city street address of well if located within city?
1/2 MILE NORTH OF INTERSECTION 120th AND LIMESTONE RD. WEST SIDE

2 WATER WELL OWNER: BRENTON KINDALL	RR#, St. Address, Box # : 403 E. CHESTNUT ST.	Board of Agriculture, Division of Water Resources Application Number:
City, State, ZIP Code : MINNEAPOLIS, KS. 67467		

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL 110 ft. ELEVATION:
--	---

Depth(s) Groundwater Encountered **59** **59** ft. 2 ft. 3 **7-29-03** ft.

WELL'S STATIC WATER LEVEL **59** ft. below land surface measured on mo/day/yr **7-29-03** ft.

Pump test data: Well water was **85** ft. after **1** hours pumping **15** gpm

Est. Yield **45** gpm: Well water was ft. after hours pumping gpm

WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 2 Irrigation 4 Industrial 7 Domestic (lawn & garden) 10 Monitoring well

Was a chemical/bacteriological sample submitted to Department? Yes No **X** ; if yes, mo/day/yr sample was submitted
 Water Well Disinfected? Yes **X** No

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued X Clamped
------------------------------	----------------	-----------------	---

Blank casing diameter **5** in. to **95** ft., Dia in. to ft., Dia in. to ft.

Casing height above land surface **20** in., weight **160** lbs./ft. Wall thickness or gauge No. **SDR 26**

TYPE OF SCREEN OR PERFORATION MATERIAL:	7 PVC	10 Asbestos-Cement
---	-------	--------------------

SCREEN OR PERFORATION OPENINGS ARE:

3 Mill slot .025	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
-------------------------	------------------	-----------	---------------------

SCREEN-PERFORATED INTERVALS: From **95** ft. to **110** ft., From ft. to ft.

GRAVEL PACK INTERVALS: From **25** ft. to **77** ft., From **80** ft. to **110** ft., From ft. to ft.

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	<u>3 Bentonite</u>	4 Other
-------------------	---------------	----------------	--------------------	---------------

Grout intervals: From **5** ft. to **25** ft., From **77** ft. to **80** ft., From ft. to ft.

What is the nearest source of possible contamination:

1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
---------------	-----------------	-------------	-------------------	-------------------------

Direction from well? How many feet?

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	7	SANDY CLAY TAN			
7	8	CLAY LIGHT GRAY			
8	80	SANDSTONE LIGHT BROWN			
80	110	SANDSTONE LIGHT TAN			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) <u>constructed</u> , (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 7-29-03 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's Licence No 388 This Water Well Record was completed on (mo/day/yr) 7-29-03 under the business name of PESTINGER PUMP SERVICE by (signature) <i>[Signature]</i>
--

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5522. Send one to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well.