

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

DRB

1. Location of well: County SHERMAN Fraction NW 1/4 SE 1/4 NW 1/4 SE 1/4 Section number 4 Township number T 10 S R 42 Range number 42

2. Distance and direction from nearest town or city: 0.51 E 1/2 N 3. Owner of well: DEIBERT WAIP  
Street address of well location if in city: KANORADO, KANS. R.R. or street: KANORADO, KANSAS  
City, state, zip code: 67741

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 24 in. Completion date 2-21-76  
Well depth 241 ft.  
7.  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary  
8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other  
9. Casing: Material Steel Height: Above or below  
Threaded  Welded  Surface 8 in.  
RMP  PVC  Weight 32 lbs./ft.  
Dia. 8 in. to 14 1/2 ft. depth Wall Thickness: inches or  
Dia. 8 in. to 14 1/2 ft. depth gage No. 188

5. Type and color of material	From	To
Clay Gravel & Sandstone	0	91
Sand & Gravel	91	103
Sandy clay	103	113
Gravel	113	119
Sandstone & Clay	119	144
Gravel	144	148
Clay & Sandstone	148	182
Sand	182	196
Clay	196	209
Gravel	209	223
Soapstone	223	235
Shale	235	241
(Use a second sheet if needed)		

10. Screen: Manufacturer's name W.A. BROWN  
Type MILLSALT Dia. 16"  
Slot/gauze 1/8 Length 100  
Set between 141 ft. and 241 ft.  
Gravel pack?  Size range of material 3/8 X 3/4  
11. Static water level: 91 ft. below land surface Date 4-16-76 mo./day/yr.  
12. Pumping level below land surfaces:  
600 ft. after 8 hrs. pumping 608 g.p.m.  
608 ft. after 16 hrs. pumping          g.p.m.  
Estimated maximum yield 608 g.p.m.  
13. Water sample submitted:          mo./day/yr.  
 Yes  No Date           
14. Well head completion:  
 Pitless adapter          inches above grade  
15. Well grouted?   
With:  Neat cement  Bentonite  Concrete  
Depth: From 8 in. to 10 ft. below  
16. Nearest source of possible contamination: Field  
ft.          Direction          Type           
Well disinfected upon completion?  Yes  No  
17. Pump:  Not installed  
Manufacturer's name           
Model number          HP          Volts           
Length of drop pipe          ft. capacity 608 g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

18. Elevation: Topography:  Hill  Slope  Upland  Valley  
19. Remarks: Concrete Run By 3573 (TOTO) Foust Supply Co Inc.

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Foust Supply Co Inc  
Business name          License No.           
Address GOODLAND, KANS.  
Signed Ralph E. Egan Date 2-25-76  
Authorized representative

10 42 E - 4 NW 1/4 SE