USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ottawa	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 21	Township number T 10 S	Range number R 5 E/W

2. Distance and direction from nearest town or city: ½ North

Street address of well location if in city: Ada

3. Owner of well:
R.R. or street: Roy Hauck (Chairman)
Ottawa Co. Water Dist. # 1
City, state, zip code: Ada, Kansas 67414

4. Locate with "X" in section below: Sketch map:

N

NW	NE
SW	SE
X	

W ——— E

S

1 Mile

6. Bore hole dia. 15 in. Completion date
Well depth 150 ft. 5/15/1978

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: __ Domestic X Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material PVC | Height: Above or below
Threaded __ Welded __ | Surface 36 in.
RMP __ PVC X | Weight 7 lbs./ft.
Dia. 8 in. to 150 ft. depth | Wall Thickness: inches or
Dia. __ in. to __ ft. depth | gage No. .332

5. Type and color of material	From	To
topsoil	0	5
brown clay	5	8
rocky	8	11
sandrock	11	24
rock w/ clay layers	24	28
gray clay	28	44
red clay	44	66
rock	66	69
gray clay	69	95
sandrock	95	153
blue clay (stop)	153	
(Use a second sheet if needed)		

10. Screen: Manufacturer's name Certainteed
Type PVC Dia. 8"
Slot/gauze 1/16" Length 55'
Set between 95 ft. and 150 ft.
__ ft. and __ ft.
Gravel pack yes Size range of material ¼x3/8"

11. Static water level:
60 ft. below land surface Date 5/1/1978 mo./day/yr.

12. Pumping level below land surfaces:
na ft. after na hrs. pumping __ g.p.m.
__ ft. after __ hrs. pumping __ g.p.m.
Estimated maximum yield 300 g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes X No Date __

14. Well head completion:
X Pitless adapter 36 Inches above grade

15. Well grouted? yes
With: X Neat cement __ Bentonite __ Concrete
Depth: From 0 ft. to 90 ft.

16. Nearest source of possible contamination:
ft. 1500 Direction nw Type lots
Well disinfected upon completion? X Yes __ No

17. Pump: __ Not installed
Manufacturer's name Jacuzzi
Model number __ HP 7½ Volts 220
Length of drop pipe 142 ft. capacity 100 g.p.m.
Type:
X Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

18. Elevation: ~1330
Topography:
X Hill
__ Slope
__ Upland
__ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report
is true to the best of my knowledge and belief.
Business name Daryl Cox & Sons Inc. 359 License No.
Address Clifton, Kans 66937
Signed Daryl Cox Date 5/15/78
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 10 R 5 W Sec 21 1/4 1/4 1/4 SE SE SW

M1-1023