

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County OTTAWA	Fraction NW 1/4 SW 1/4 SW 1/4	Section number 33	Township number T 10 S R 5	Range number 5	
2. Distance and direction from nearest town or city: 1 SOUTH			3. Owner of well: KEITH BACON				
Street address of well location if in city: ADA			R.R. or street: City, state, zip code: ADA, KANS 67414				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 9-21-78 Well depth 80 ft.			
		<p>7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia 5 in. to 80 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258</p>		10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot gauze 1/16" Length 20' Set between 60 ft. and 80 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/4" - 1/2"			
				5. Type and color of material			11. Static water level: <input type="checkbox"/> mo./day/yr. 20 ft. below land surface Date 9-21-78
		From		To		12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after 1 1/2 hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 20 g.p.m.	
						13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
						15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
						16. Nearest source of possible contamination: ft. 80 Direction SW Type LOTS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PARYL COX + SONS INC 359 Business name License No. Address ELLIOTTON, KANS 66937 Signed PARYL COX Date 10-1-78 Authorized representative	
18. Elevation: 1375		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

T 10 S R 5 33 NW SW SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5