


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Russell	Township name Waldo	Fraction NW¹/₄ NE¹/₄	Section number 33	Town number 11 S	Range number 13W		
Distance and direction from nearest town or city: 2 mi. east and 4 1/2 South of Waldo Street address of well location if in city:				3 Owner of well: Bob Swiffel Address: Waldo Kansas				
Locate with "X" in section below: N  W E S 1 Mile				Sketch map: Well is about 150' west of dwelling and 100' and 100' Northwest of barn.		4 Well depth: <u>46</u> ft. Date of completion <u>3/22-76</u> Well diameter <u>10</u> in.		
2 Type and color of material				From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				Black top soil		0	4'	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
				Yellow Clay		4'	30	7 Casing: Material <u>PVC</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. _____ Weight <u>2</u> lbs./ft. _____ <u>5</u> in. to <u>46</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth
				Sandy soil		30	35	8 Screen: Manufacturer <u>Self made</u> Type _____ Dia. <u>5"</u> Slot/size <u>1/16"</u> Length <u>8'</u> Set between <u>31</u> ft. and _____ ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____
				Coarse sand		35	40	9 Static water level: <u>31</u> below land surface Date <u>3/22</u>
				Blue shale		40	46	10 Pumping level below land surfaces: <u>35</u> ft. after <u>2</u> hrs. pumping <u>7</u> g.p.m. <u>35</u> ft. after <u>6</u> hrs. pumping <u>7</u> g.p.m. Estimated maximum yield <u>7</u> g.p.m.
								11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
								12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> _____ inches above grade
								13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>16</u> ft. to <u>5</u> ft.
								14 Nearest source of possible contamination: ft. <u>100'</u> Direction <u>South</u> Type <u>barn</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
16 Remarks: elevation Well is on slope-up grade from buildings				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Oscar Rush License No. 310 Business name <u>Natoma, Kansas</u> Address _____ Signed <u>Oscar Rush</u> Date <u>4/20/76</u> Authorized representative				

11 13W 33 NWNE

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5