

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County ELLIS	Township name CATHERINE	Fraction North North West	Section number 16	Town number T-11-S	Range number 16W
Distance and direction from nearest town or city: Street address of well location if in city:				3 Owner of well: Address:		
1 1/2 South of PLAINVILLE 10 1/2 EAST				Gene CRAIG NATOMA KANS		
Locate with "X" in section below: N W E S 1 Mile		Sketch map:		4 Well depth: 35 ft. Date of completion: 6/22/79 Well diameter: 8 1/2 in.		
2 Type and color of material		From To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> LIVE STOCK		
				7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 1/2 in. Diam. Weight 200 lbs./ft. 0.280 6 in. to 35 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth		
				8 Screen: None - used perforated Manufacturer CASINS Type PVC Dia. 6 Slot/gauze 1/2 Length 3 ft. 2 in. Set between 12 ft. and 30 ft. 13 Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 4/8		
				9 Static water level: 15 ft. below land surface Date 6/22/79		
				10 Pumping level below land surfaces: — ft. after — hrs. pumping — g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 30 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 28 inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> — Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: None ft. — Direction — Type — Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name — Model number — HP — Volts — Length of drop pipe — ft. capacity — g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation OWNER WILL FINISH WELL TO STATE REQUIREMENTS		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JAMES BRAS WATER Well Drg 285 Business name License No. — Address Box 68 RR 2 PLAINVILLE KS Signed [Signature] Date 7/17/79 Authorized representative		

11 16W 16 NUNNAN