

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

NE SE

1 Location of well:	County ELLIS	Township name Riverview	Fraction SE 1/4	Section number 2	Town number 11	Range number 19
Distance and direction from nearest town or city: 6 miles south			3 Owner of well: ADOLPH BILLING			
Street address of well location if in city: Zurich 2 miles East			Address: Zurich, KANSAS			
Locate with "X" in section below:			Sketch map		4 Well depth: 92 ft. Date of completion 12-10-75 Well diameter 9 in.	
					5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
					7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. Diam. 5 in. to 92 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 92 ft. depth	
2			Type and color of material		8 Screen:	
			From To		Manufacturer Jesse Lowell	
			Black dirt 0 14		Type PVC Dia. 5"	
			White shale 14 46		Slot/gauze 1/8 Length 10'	
			Blue shale 46 78		Set between 92 ft. and 82 ft.	
			Fine sand 78 84		Fittings:	
			Water gravel 84 92		Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material ---	
					9 Static water level: 80 ft. below land surface Date 12-10-75	
					10 Pumping level below land surfaces: 80 ft. after 2 hrs. pumping 20 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 40 g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
					12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 50 ft. to 20 ft.	
					14 Nearest source of possible contamination: ft. 20 Direction South Type Earth lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Dempster Model number _____ HP 1/2 Volts 230 Length of drop pipe 86 ft. capacity 20 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(use a second sheet if needed)			
16 Remarks: elevation					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. P.J. Well Drilling 269A Business name _____ License No. _____ Address Palco, Kansas Signed Paul Schell Date 2-1-76 Authorized representative	

11 19 W 2 SE

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5