

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

HUXIE 45E

WATER WELL RECORD
KSA 82-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Trego		Fraction SW 1/4 SE 1/4 SE 1/4		Section number 2	Township number T 11 S R 25 E/W	Range number 25
2. Distance and direction from nearest town or city: 6 mi & 2 W Street address of well location if in city: Koda, Kan.				3. Owner of well: A. N. Tidwell R.R. or street: R.R. City, state, zip code: Colyer, Kan 67631		
4. Locate with "X" in section below: N NW NE SW SE S 1 Mile W E				Sketch map: 		
5. Type and color of material				From	To	6. Bore hole dia. 7 in. Completion date: 3-1-77 Well depth 31-77 ft.
clay				0	22	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
sand (fine)				22	29	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
clay				29	35	9. Casing: Material plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 24 lbs./ft. Dia. 5 in. to 54 ft. depth Wall Thickness: inches or Dia. 5 in. to 54 ft. depth gage No. 250
Blue mud				35	44	10. Screen: Manufacturer's name JESS 1 1/2" x 11" Type plastic Dia. 5" Slot/gauze 3/16 Length 10" Set between 4 1/2 ft. and 5 1/2 ft. ft. and 5 1/2 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4" to 1/8"
sand & blue mud STRIPS				44	50	11. Static water level: 28 ft. below land surface Date 3-1-77 mo./day/yr.
Blue shale				50	51	12. Pumping level below land surface: 20 ft. after 20 hrs. pumping 10 g.p.m. 22 ft. after 20 hrs. pumping 10 g.p.m. Estimated maximum yield _____ g.p.m.
ROCK 50'						13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
50 28 22' sat h.						14. Well head completion: Pitless adapter NOT DONE inches above grade
2342						15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 6 ft. to 16 ft.
22' sat thick - possible Og (1/2 mi)						16. Nearest source of possible contamination: ft. 160 Direction SE Type COSS Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
sol contact - probably a alluvium						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
A sol. flow						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DLT Drilling Co 303 Business name _____ License No. _____ Address Hill City, Kan Signed Allen [Signature] Date 11-18-77 Authorized representative
(Use a second sheet if needed)						
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: Landowner to put in slab. 2360 (TOPO)				

T 11 S R 25 E 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5