

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

HOXIE 4SE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ABA

1. Location of well:		County TREGO	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 26	Township number T 11 S	Range number R 25 E (M)
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: ART. ZEIGLER R.R. or street: City, state, zip code: COLLIER Ks. 67631 MNC			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			
5. Type and color of material			From	To	6. Bore hole dia. 9 in. Completion date 5-11-77 Well depth 75 ft.	
Top soil			0	9	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
sandy clay			9	14	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
gravel			14	16	9. Casing: Material _____ Height: above or below Threaded _____ Welded _____ Surface 1 1/2" in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 2 in. to 25 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200	
sandy clay + S.S.			16	65	10. Screen: Manufacturer's name less howell Type pvc Dia. 5 Slot/gauze 1/32 Length 8' Set between 64 ft. and 72 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-1/4	
sandy clay + fine sand.			65	72	11. Static water level: _____ mo./day/yr. 55 ft. below land surface Date 5-11-77	
Ocher.			72	75	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 + g.p.m.	
72 BROOK 72'					13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
55' sat th.					14. Well head completion: <input type="checkbox"/> Pitless adapter 12" inches above grade	
2459 72 2387					15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
17' sat thick possible Og. (1/2 mile)					16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
S.S. contact in Alluvium					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal mill Other _____	
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRUCKHOFF SONS 299 Business name _____ License No. _____ Address GRINNELL Ks. Signed [Signature] Date 6-9- Authorized representative	
18. Elevation:		19. Remarks: 2459 (TOPO)				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

11 250 26 NE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5