


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

ACC

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>LOGAN</u>	Township name	Fraction <u>SW-SW-NE</u>	Section number <u>2</u>	Town number <u>11 S</u>	Range number <u>32 W</u>
Distance and direction from nearest town or city: <u>Approx 1 mile East of Oakley</u>			3 Owner of well: <u>Ben Keller Bros.</u>			
Street address of well location if in city:			Address: <u>Page City, Ks. 67750</u>			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: <u>220</u> ft. Date of completion <u>5-31-76</u> Well diameter <u>28</u> in.
			5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
			7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>1 1/2</u> in. Diam. Weight <u>.219 lb/ft.</u> <u>12 3/4</u> in. to <u>220</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
2 Type and color of material			From	To	8 Screen: Manufacturer <u>W.A. Brown</u> Type <u>510T Steel</u> Dia. <u>1 1/2 3/4</u> Slot/gauze <u>10/32</u> Length <u>30</u> Set between <u>200</u> ft. and <u>220</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>4-8</u>	
Topsoil, Clay silty, brown			0	120	9 Static water level: <u>120</u> ft. below land surface Date <u>4-30-76</u>	
Med Gravel, Fine sand, Traces sandstone			120	132	10 Pumping level below land surfaces: <u>200</u> ft. after <u>8</u> hrs. pumping <u>208</u> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>208</u> g.p.m.	
Sandy clay, Fine sand, Med Gravel brown			132	150	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Sandy clay, Fine sand, Clay gummy, brown			150	158	12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Sandy clay, Sand stone, Med Gravel, Fine sand			158	164	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>1</u> ft. to <u>10</u> ft.	
Sandstone, white			164	165	14 Nearest source of possible contamination: <u>unknown</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Med Gravel, Fine sand, Sandy clay, Sandstone			165	184	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Gould</u> Model number <u>85HC</u> HP <u>75</u> Volts <u>460</u> Length of drop pipe <u>210</u> ft. capacity <u>900</u> g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Med Gravel, Fine sand, Trace Sandstone			184	187	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Red Tiger Irrigation</u> <u>125</u> Business name License No. Address <u>Colby Kansas</u> Signed <u>B. B. R. G.</u> Date <u>5-16-76</u> Authorized representative	
Sandy clay, Sandstone, Clay, gummy, brown			187	203		
Sandy clay, Fine sand, Clay gummy, brown			203	209		
Med Gravel, Fine sand			209	217		
Ochrea, yellow, Shale, blue			217	220		
BROCK 217						
(use a second sheet if needed)						
16 Remarks: elevation Concrete slab installed by driller before pump was set. Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

11 3200 2 SUSSENE