

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DHI

1. Location of well:		County LOGAN	Fraction SE 1/4 NE 1/4 SE 1/4	Section number 10	Township number T 11 S R 32 (EW)	Range number
2. Distance and direction from nearest town or city: OAKLEY KS			3. Owner of well: HARRY JOHNSON			
Street address of well location if in city: 15			R.R. or street: R.P.			
			City, state, zip code: Oakley KS			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 11-30-77		
				Well depth 208 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 208 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200
top soil		0		27		10. Screen: Manufacturer's name less lowell
sandy clay		27		48		Type PVC Dia. 5
m. gravel		48		55		Slot/gauze 1/8 Length 8'
sandy clay		55		102		Set between 195 ft. and 203 ft. _____ ft. and _____ ft.
m. gravel		102		107		Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 x 1/4
sandy clay		107		123		11. Static water level: _____ mo./day/yr. 98 ft. below land surface Date 11-30-77
gravel		123		136		12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 plus g.p.m.
sand stone		136		137		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
sandy clay		137		139		14. Well head completion: <input type="checkbox"/> Pitless adapter N/A Inches above grade
m. gravel		139		142		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
sandy clay		142		155		16. Nearest source of possible contamination: ft. _____ Direction _____ Type gravel
m. gravel		155		162		Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
sandy clay		162		171		17. Pump: <input checked="" type="checkbox"/> Not installed
m. gravel		171		183		Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m.
sandy clay		183		202		Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
gravel		202		203		(Use a second sheet if needed)
18. Elevation:		19. Remarks: Oakley 203 508				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STUCKHOFF SONS 298 Business name _____ License No. _____ Address GRINNELL KS Signed Stuckhoff Date 12-4-77 Authorized representative				

T 11 320 E L O SE NE SE
R
Sec
1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5