

Sent to OWS
12/7/78

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

AAA

1. Location of well:		County LOGAN	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 10	Township number T 11 S R 32	Range number 32
2. Distance and direction from nearest town or city: Street address of well location if in city: CITY LIMITS				3. Owner of well: CITY OF DAKLEY R.R. or street: City, state, zip code: DAKLEY KANSAS 67748		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: Well DRAINAGE SEWER PLANT				6. Bore hole dia. 36 in. Completion date _____ Well depth 230 ft. 4-12-76		
5. Type and color of material				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Clay, Sand STRAKS				8. Use: Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy Clay				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 62 lbs./ft. Dia. 16 in. to 16A ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 325		
M GRAVEL				10. Screen: Manufacturer's name DOERR & COOK Type LUGER Dia. 16 Slot/gauze 1/8-250 Length 70 Set between 160 ft. and 230 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/8		
M GRAVEL, Sandy Clay				11. Static water level: _____ mo./day/yr. 111 ft. below land surface Date 4-7-76		
M GRAVEL				12. Pumping level below land surfaces: 810 ft. after 10 hrs. pumping 950 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 950 g.p.m.		
Sandy Clay				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
M GRAVEL				14. Well head completion: <input type="checkbox"/> Pitless adapter 36 inches above grade		
Sandy Clay				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
M GRAVEL				16. Nearest source of possible contamination: SEWER PLANT ft. 356 Direction SW Type PLANT Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sandy Clay, Trace GRAVEL				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name BYRON JACKSON Model number 6 HP 100 Volts 440 Length of drop pipe 210 ft. capacity 200 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Dchae				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. St H Dilling Co Inc 146 Business name _____ License No. _____ Address Sholland Kansas Signed Bill Chaffin Date 4-25-76 Authorized representative		
BROCK 229						
18. Elevation:				19. Remarks:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

L L 320 L O NE NE NE
 Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5