

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County OTTOWA	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 11	Township number T 12 S R 2 E W	Range number
2. Distance and direction from nearest town or city: 4 E 1/4 S			3. Owner of well: GEORGE ORNER JR			
Street address of well location if in city: BENNINGTON			R.R. or street: RR ROUTE			
			City, state, zip code: BENNINGTON, KANS 67422			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date		
				Well depth 55 ft. 12-16-77		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 2 in. to 55 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258		
TOPSOIL		0	5	10. Screen: Manufacturer's name PUMPCO		
RED CLAY		5	13	Type PVC Dia. 5"		
BROWN CLAY		13	20	Slot gauze 1/16 Length 20'		
SAND		20	23	Set between 35 ft. and 55 ft. ft. and <input type="checkbox"/> ft.		
BROWN CLAY		23	33	Gravel pack? YES Size range of material 18X14		
FINE SAND		33	38	11. Static water level: <input type="checkbox"/> mo./day/yr. 20 ft. below land surface Date 12-16-77		
GRAVEL		38	50	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after N/A hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.		
SHALE		50	55	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
STOP		55		14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: FEED ft. 50 Direction SOUTH Type LAT Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Geo Cox Sons Inc 258 Business name License No. _____ Address CLIFTON, KANS 66937 Signed Ray Cox Date 12-16-77 Authorized representative		
18. Elevation: 1259		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

12-20-77
 Sec 11
 1/4 NW 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5