


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Ottawa	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 33	Township number T 12 S	Range number R 24 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 2 1/2 E - 51. of Bennington			3. Owner of well: Gary Weis R.R. or street: 808 N. 10th City, state, zip code: Salina Ks 67401		
4. Locate with "X" in section below: N  W E S 1 Mile			6. Bore hole dia. 4 in. Completion date Oct 20, 1976 Well depth 36 ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From			9. Casing: Material _____ Height: above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 36 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. Sched 40		
			10. Screen: Manufacturer's name Shap Type slots Dia. 4 Slot/gauze 1/16 Length 10 Set between 26 ft. and 36 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/16"		
Alluvium:			11. Static water level: _____ mo./day/yr. 16 ft. below land surface Date 10-20-76		
Clay, silty, buff			12. Pumping level below land surfaces: _____ ft. after 1 hrs. pumping 2 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 2 g.p.m.		
Gravel, coarse & sand, fine			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay, silty buff			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Gravel, coarse to fine & sand			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
Clay, buff			16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Gravel, coarse to fine & sand, silty			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Silty, sandy, buff			(Use a second sheet if needed)		
Gravel, coarse to fine, sand, fine & silt					
Wellington fm:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydraulic Drilling Co 126 Business name, License No. Address Salina Ks Signed Ed Fant 12-2-76 Date Authorized representative		
18. Elevation: 1242 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		19. Remarks:			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5