


Serial 5-77

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Yrego	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 23	Township number 12	Range number 22
2. Distance and direction from nearest town or city: Street address of well location if in city: OG Allah Ks.			3. Owner of well: Martha Brabb R.R. or street: City, state, zip code: OGallah Kansas		
4. Locate with "X" in section below:  Sketch map: well → X House road septic tank			6. Bore hole dia. 9 in. Completion date 8-1-75 Well depth 120 ft.		
5. Type and color of material			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Topsail Subsoil Yellow Clay Fine sand Blue shale			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From To 0 4 4 20 20 35 35 110 110 120			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 15 lbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or Dia. 5 in. to 120 ft. depth gage No. 258		
			10. Screen: Manufacturer's name ET Stream		
			Type PVC Dia. 5" Slot gauge 15' Length 15' Set between 100 ft. and 115 ft. ft. and 115 ft.		
			Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4		
			11. Static water level: 85 ft. below land surface Date 8-1-75		
			12. Pumping level below land surfaces: 88 ft. after 1 hrs. pumping 10 g.p.m. ft. after 1 hrs. pumping 10 g.p.m. Estimated maximum yield 10 g.p.m.		
			13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 8-1-75		
			14. Well head completion: Pitless adapter 18 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 1 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 15 Direction S Type septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Not installed		
			Manufacturer's name F+W Model number 7847 HP 3/4 Volts 220 Length of drop pipe 110 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karstwater Well 199A Business name E Hwy 40 License No. 1/4 Address Phil Karst Date 8/1/75 Signed Phil Karst Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5