

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

CCC

CONCRETE

1. Location of well: County <u>Trego</u> Fraction <u>SW 1/4 SW 1/4 SW 1/4</u> Section number <u>11</u> Township number <u>T 12 S</u> Range number <u>R 25 EW</u>	
2. Distance and direction from nearest town or city: <u>3 miles east of Collyer, KS.</u> 3. Owner of well: <u>EIMER JACOBITZ</u> R.R. or street: <u>R.R.</u> City, state, zip code: <u>Collyer, Kans. 67631</u>	
4. Locate with "X" in section below: Sketch map: 	
5. Type and color of material	
6. Bore hole dia. <u>9</u> in. Completion date <u>6-22-77</u> Well depth <u>84</u> ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <u>PLST.</u> Height: <u>(Above)</u> or below Threaded <input type="checkbox"/> Welded <u>91</u> Surface <u>24</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>80</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>1250</u>	
10. Screen: Manufacturer's name <u>Jess &amp; Howell</u> Type <u>plastic</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>10'</u> Set between <u>70</u> ft. and <u>80</u> ft. _____ ft. and _____ ft. Gravel pack? <u>YES</u> Size range of material <u>1/4 to 5/8</u>	
11. Static water level: _____ mo./day/yr. <u>51</u> ft. below land surface Date <u>6/20/77</u>	
12. Pumping level below land surfaces: <u>NOT PUMPED</u> _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
14. Well head completion: <u>NOT DONE</u> <input type="checkbox"/> Pitless adapter _____ inches above grade	
15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>5</u> ft. to <u>15</u> ft.	
16. Nearest source of possible contamination: ft. <u>300</u> Direction <u>SE</u> Type <u>cesspool</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <u>NOT</u> <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: <u>level</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <u>CONCRETE SLAB TO BE INSTALLED BY CUSTOMER.</u> <u>2525 7000</u>
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>D&amp;L DRILLING Co 303</u> Business name _____ License No. _____ Address <u>Bx 368, Hill City, KS 67644</u> Signed <u>Allard Tomlin</u> Date <u>1-77</u> Authorized representative	

T 22 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5