

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gove	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 3	Township number T 12 S	Range number R 28 E	<div style="border: 1px solid black; padding: 5px; display: inline-block;"> DR EW </div>
2. Distance and direction from nearest town or city: 4 S - 4 E		3. Owner of well: John Kaiser					
Street address of well location if in city: 06 Grainfield		R.R. or street: Grainfield, Kansas 67737					
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 8 in. Completion date 5/5/77		
<div style="text-align: center;"> </div>					Well depth 53 ft.		
<div style="text-align: center;"> </div>					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug		
					<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
					<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock		
					9. Casing: Material ptls Height: abv or below		
					Threading Welded Surface 81 in.		
					RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 10 lbs./ft.		
					Dia. 5 in. to 53 ft. depth Wall Thickness: inches or		
					Dia. 5 in. to 53 ft. depth gauge No. 12		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Valley Steel			
Silt + clay		0	20	Type PVC Dia. 5 in.			
sand + clay		20	40	Slot/gauze 1/2 Length 20 ft.			
gravel		40	50	Set between 43 ft. and 53 ft.			
yellow clay		50	53	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 down			
				11. Static water level: 22 ft. below land surface Date 5/5/77			
				12. Pumping level below land surfaces:			
				____ ft. after ____ hrs. pumping ____ g.p.m.			
				____ ft. after ____ hrs. pumping ____ g.p.m.			
				Estimated maximum yield 10 g.p.m.			
				13. Water sample submitted: ____ mo./day/yr.			
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____			
				14. Well head completion:			
				____ Pitless adapter ____ Inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/>			
				With clay Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/>			
				Depth: From 0 ft. to 20 ft.			
				16. Nearest source of possible contamination:			
				ft. ____ Direction ____ Type ____			
				Well disinfected upon completion? ____ Yes ____ No			
				17. Pump: <input checked="" type="checkbox"/> Not installed			
				Manufacturer's name ____			
				Model number ____ HP ____ Volts ____			
				Length of drop pipe ____ ft. capacity ____ g.p.m.			
				Type:			
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine			
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating			
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		(Use a second sheet if needed)			20. Water well contractor's certification:		
Topography:					This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Hill					Aqua Well Drilling 281		
<input checked="" type="checkbox"/> Slope					Business name License No.		
<input checked="" type="checkbox"/> Upland					Address Gove, Ks. 67736		
<input type="checkbox"/> Valley					Signed J. M. Intelle Date 6-20-77		
					Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5