

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

HAC

1. Location of well: County GOVE Fraction SW 1/4 NE 1/4 NE 1/4 Section number 3 Township number T 12 S R 31 E 40

2. Distance and direction from nearest town or city: 5-3. 3. Owner of well: LUKE RACETTE
Street address of well location if in city: CAMPUS Ks. R.R. or street:
City, state, zip code: OAKLEY Ks.

4. Locate with "X" in section below: Sketch map:
N
1 Mile
W E
S
1 Mile

6. Bore hole dia. 9 in. Completion date 6-1-79
Well depth 105 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material _____ Height: Above or below
Threaded _____ Welded _____ Surface 12" 1 in.
RMP _____ PVC Weight _____ lbs./ft.
Dia. 5 in. to 105 ft. depth Wall Thickness: inches or
Dia. _____ in. to _____ ft. depth gage No. 200

5. Type and color of material	From	To
<u>top soil</u>	<u>0</u>	<u>19</u>
<u>sandy clay</u>	<u>19</u>	<u>22</u>
<u>m gravel</u>	<u>22</u>	<u>48</u>
<u>fine sand</u>	<u>48</u>	<u>50</u>
<u>sandy clay</u>	<u>50</u>	<u>55</u>
<u>gravel</u>	<u>55</u>	<u>57</u>
<u>sandy clay + S.S.</u>	<u>57</u>	<u>69</u>
<u>m. gravel</u>	<u>69</u>	<u>79</u>
<u>sandy clay</u>	<u>79</u>	<u>105</u>
<u>Ocher</u>	<u>105</u>	

10. Screen: Manufacturer's name less Lowell
Type pvc Dia. 5
Slot/gauze 1/32 Length 8'
Set between 71 ft. and 79 ft.
_____ ft. and _____ ft.
Gravel pack? Size range of material 1/8-1/4

11. Static water level: _____ mo./day/yr.
62 ft. below land surface Date _____

12. Pumping level below land surfaces:
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 20 + g.p.m.

13. Water sample submitted: _____ mo./day/yr.
 Yes No Date _____

14. Well head completion:
 Pitless adapter 12" inches above grade

15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 200' Direction South Type DRW
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal mill Other

(Use a second sheet if needed)

18. Elevation:
Topography:
 Hill
 Slope
 Upland
 Valley

19. Remarks:
2972 (TOPO)

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
STRUCKHOFF SONS 298
Business name License No.
Address GRINNELL Ks
Signed [Signature] Date 6-9-79
Authorized representative

T 12 31 E 40
R
Sec 3
SW NE NE
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5