

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: OTTAWA	SW ¼ SW ¼ NE ¼	9	T 12 S	R 4 EW

Distance and direction from nearest town or city street address of well if located within city?

2 WATER WELL OWNER: JOHN PERRY
 RR#, St. Address, Box # : 437 N. 60th RD. Board of Agriculture, Division of Water Resources
 City, State, ZIP Code : ESCOTT, KS. 67484 Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL 95.5 ft. ELEVATION:										
<table border="1" style="margin: auto; border-collapse: collapse;"> <tr><td colspan="2" style="text-align: center;">N</td></tr> <tr><td style="text-align: center;">-NW-</td><td style="text-align: center;">-NE-</td></tr> <tr><td style="text-align: center;">W</td><td style="text-align: center;">X</td></tr> <tr><td style="text-align: center;">-SW-</td><td style="text-align: center;">-SE-</td></tr> <tr><td colspan="2" style="text-align: center;">S</td></tr> </table>	N		-NW-	-NE-	W	X	-SW-	-SE-	S		Depth(s) Groundwater Encountered 1 65 ft. 2 ft. 3 ft. WELL'S STATIC WATER LEVEL 65 ft. below land surface measured on mo/day/yr 21-NOV. 02 Pump test data: Well water was 75 ft. after 3/4 hours pumping 15 gpm Est. Yield 40 gpm: Well water was ft. after hours pumping gpm WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Domestic (lawn & garden) 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes No <u>X</u>; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes <u>X</u> No
N											
-NW-	-NE-										
W	X										
-SW-	-SE-										
S											

5 TYPE OF BLANK CASING USED:

1 Steel	3 RMP (SR)	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued <u>X</u> Clamped
2 PVC	4 ABS	6 Asbestos-Cement	9 Other (specify below)	Welded
		7 Fiberglass		Threaded

Blank casing diameter 5 in. to 85.5 ft., Dia in. to ft.
 Casing height above land surface 20 in., weight 160 lbs./ft. Wall thickness or gauge No. SDR 26

TYPE OF SCREEN OR PERFORATION MATERIAL:

1 Steel	3 Stainless Steel	5 Fiberglass	8 RMP (SR)	10 Asbestos-Cement
2 Brass	4 Galvanized Steel	6 Concrete tile	9 ABS	11 Other (Specify)
				12 None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE:

1 Continuous slot	3 Mill slot .025	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes	
		7 Torch cut	10 Other (specify)	ft.

SCREEN-PERFORATED INTERVALS: From 85.5 ft. to 95.5 ft., From ft. to ft.
 GRAVEL PACK INTERVALS: From 22 ft. to 56 ft., From 59 ft. to 95.5 ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other

Grout intervals: From 0 ft. to 22 ft., From 56 ft. to 59 ft., From ft. to ft.

What is the nearest source of possible contamination:

1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
			13 Insecticide storage	

Direction from well? NORTH How many feet? 65

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	1	TOP SOIL			
1	16	CLAY LIGHT GRAY			
16	17	SANDSTONE GOLD			
17	26	CLAY LIGHT GRAY WITH SANDSTONE LAYERS			
26	29	SANDSTONE RED			
29	38	CLAY LIGHT GRAY			
38	42	SANDSTONE BROWN			
42	50	CLAY LIGHT GRAY			
50	65	SANDSTONE BROWN			
65	66	CRACK IN SANDSTONE			
66	96	HAD TO DRILL HOLE BLIND DRILLED LIKE IT WAS SANDSTONE			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 11-21-02 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's Licence No 388 This Water Well Record was completed on (mo/day/yr) 11-21-02 under the business name of PESTINGER PUMP SERVICE by (signature) *[Signature]*

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5522. Send one to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well.