


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County LINCOLN	Township name	Fraction NENE	Section number 26	Town number 125	Range number 7W
Distance and direction from nearest town or city: 3 S 5 E Street address of well location if in city: LINCOLN, KANS				3 Owner of well: Gerald Walten Address: LINCOLN, KANS		
Locate with "X" in section below: 				4 Well depth: 51 ft. Date of completion 7-2-75 Well diameter 30 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
From To				7 Casing: Material IRON Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. Diam. 16 in. to 31 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				8 Screen: Manufacturer Doerr's Type IRON Dia. 16" Slot/gauze 1/8 Length 20 Set between 31 ft. and 51 ft. Fittings: 1/8" - 3/4" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
(use a second sheet if needed)				9 Static water level: 24 ft. below land surface Date 7-2-75		
				10 Pumping level below land surfaces: 43 ft. after 3 hrs. pumping 700 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 800 g.p.m.		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 24 Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: NONE ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kelly's Water Well Serv. Inc. Business name License No. Address R2 Great Bend, Ks Signed Kelly Price Date 7-25 Authorized representative		