

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ellis	Fraction NE 1/4 NW 1/4 SW 1/4	Section number 28	Township number T 13 S R 18 E 1	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: SAME			3. Owner of well: Celly Shumacher R.R. or street: 112 W. 34th City, state, zip code: Hays, Ks. 67601		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. <u>47</u> in. Completion date <u>9-24-77</u> Well depth <u>47</u> ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Topsoil		0	4	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown clay		4	28	9. Casing: Material <u>91</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>16</u> in. RMP <u>PVC</u> Weight <u>160 BS</u> lbs./ft.	
Fine to medium sand mixed with clay		28	37	Dia. <u>5</u> in. to <u>47</u> ft. depth Wall thickness: inches or Dia. <u>5</u> in. to <u>47</u> ft. depth gage No. <u>5</u>	
Medium sand		37	43	10. Screen: Manufacturer's name <u>Tet Stream</u> Type <u>PVC</u> Dia. <u>5"</u> Clot gauze <u>10'</u> Length <u>10'</u> Set between <u>37</u> ft. and <u>47</u> ft. ft. and <u>47</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4-1/8</u>	
Blue shale		43	47	X Static water level: <u>35</u> ft. below land surface Date <u>9-24-77</u> mo./day/yr.	
				12. Pumping level below land surfaces: <u>39</u> ft. after <u>2</u> hrs. pumping <u>10</u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>10</u> g.p.m.	
				13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>14</u> inches above grade	
				X Well grouted? <u>YES</u> With: <input type="checkbox"/> Negt cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>top</u> ft. to <u>9</u> ft.	
				16. Nearest source of possible contamination: <u>none</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <u> </u> Not installed Manufacturer's name <u>FWT</u> Model number <u>5BAR</u> HP <u>1/2</u> Volts <u>230</u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KARST Water Well Dns. Business name <u> </u> License No. <u> </u> Address <u>Hwy 40 Hays</u> <u>1977</u> Signed <u> </u> Date <u>9-24-77</u> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5