

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ellis	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 28	Township number T 13	Range number R 18	
2. Distance and direction from nearest town or city: Street address of well location if in city: 35th and Hall Hays, Ks			3. Owner of well: Van Doren Ind. R.R. or street: E. Hiway 40 City, state, zip code: Hays, Ks.			
4. Locate with "X" in section below		Sketch map:		6. Bore hole dia. 12 1/2 in. Completion date 8-25-79 Well depth 60 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
topsoil		0		4		9. Casing: Material PVC Height: 55 or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface: GI in. RMP: 8 PVC XX Weight: 5.4750 lbs./ft. Dia. 8 in. to 60 ft. depth Wall Thickness: inches or Dia. 8 in. to 60 ft. depth gage No. 332
clay (gumbo)		4		41		10. Screen: Manufacturer's name Home Type PVC Dia. 8" Slot 3/32 .031 Length 15 Set between 4 1/4 ft. and 59 ft. ft. and 3 3/4 ft.
medium gravel		41		56		Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8-3/4
blue shale		56		60		11. Static water level: 45 ft. below land surface Date 8-25-79 mo./day/yr.
						12. Pumping level below land surfaces: 47 ft. after 4 hrs. pumping 250 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 300 g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
						16. Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Wells 199 Business name _____ License No. _____ Address E. Hiway 40 Hays, Ks. Signature _____ Date 8-22-79 Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 13
 R 18
 E
 Sec
 NW SW NW
 1/4 1/4 1/4