

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Ellis Fraction NW 1/4 SW 1/4 SE 1/4 Section number 28 Township number T 13 S R 18 E Range number	
2. Distance and direction from nearest town or city: Street address of well location if in city: 2727 Willow	
3. Owner of well: Jack Curtis R.R. or street: 1203 Fort City, state, zip code: Hays, Kansas 67601	
4. Locate with "X" in section below: Sketch map:	
6. Bore hole dia. 9 in. Completion date 4/5/76 Well depth 70 ft.	
7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material PVC Height Above or below 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 70 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258	
5. Type and color of material	
	From To
Topsoil	0 4
Subsoil	4 12
Brown Clay	12 52
Gravel	52 66
Blue Shale	66 70
10. Screen: Manufacturer's name Jet Stream Type PVC Dia. 5" Slot/gauze 10' Length 10' Set between 58 ft. and 68 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4"	
11. Static water level: <input type="checkbox"/> mo./day/yr. 40 ft. below land surface Date 4/5/76	
12. Pumping level below land surfaces: 42 ft. after 1 hrs. pumping 19 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 19 g.p.m.	
13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 1 ft. to 10 ft.	
16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name F&W Model number 10 BR9 HP 1 Volts 220 Length of drop pipe 65 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: None
20. Water well contractor's certification: <input checked="" type="checkbox"/> This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Well 199A 1/4 Business name License No. 1/4 Address E. Hwy. 40 Hays 1/4 Signed cm B. Stee Date 4/5/76 1/4 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5