

1 LOCATION OF WATER WELL County: <u>Ellis</u>	Fraction <u>SE</u> $\frac{1}{4}$ <u>NW</u> $\frac{1}{4}$ <u>SW</u> $\frac{1}{4}$	Section Number <u>28</u>	Township Number <u>T 13 S</u>	Range Number <u>R 18 E/W</u>
--------------------------------------------------	-------------------------------------------------------------------------------------	-----------------------------	----------------------------------	---------------------------------

Distance and direction from nearest town or city? \_\_\_\_\_ Street address of well if located within city?  
2920 Walnut, Hays, Kansas

2 WATER WELL OWNER: Tom Hanshew  
RR#, St. Address, Box #: 2920 Walnut  
City, State, ZIP Code: Hays, Kansas 67601  
Board of Agriculture, Division of Water Resources  
Application Number: \_\_\_\_\_

3 DEPTH OF COMPLETED WELL: 80 ft. Bore Hole Diameter: 9 in. to \_\_\_\_\_ ft., and \_\_\_\_\_ in. to \_\_\_\_\_ ft.  
Well Water to be used as: 7 5 Public water supply 8 Air conditioning 11 Injection well  
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)  
2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well  
Well's static water level: 50 ft. below land surface measured on May month 3 day 1980 year  
Pump Test Data: Well water was 54 ft. after 1 hours pumping 15 gpm  
Est. Yield 25 gpm: Well water was \_\_\_\_\_ ft. after \_\_\_\_\_ hours pumping \_\_\_\_\_ gpm

4 TYPE OF BLANK CASING USED: 2 5 Wrought iron 8 Concrete tile Casing Joints: Glued  Clamped \_\_\_\_\_  
1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded \_\_\_\_\_  
2 PVC 4 ABS 7 Fiberglass Threaded \_\_\_\_\_  
Blank casing dia 5 in. to 60 ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft.  
Casing height above land surface: 24 in., weight 200 lbs./ft. Wall thickness or gauge No. .26  
TYPE OF SCREEN OR PERFORATION MATERIAL: 7 7 PVC 10 Asbestos-cement  
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) \_\_\_\_\_  
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)  
Screen or Perforation Openings Are: 8 5 Gauzed wrapped 8 Saw cut 11 None (open hole)  
1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes  
2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify) \_\_\_\_\_  
Screen-Perforation Dia: 5 in. to 80 ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft., Dia \_\_\_\_\_ in. to \_\_\_\_\_ ft.  
Screen-Perforated Intervals: From 60 ft. to 80 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft. to \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Gravel Pack Intervals: From 50 ft. to 80 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft. to \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

5 GROUT MATERIAL: 1 1 Neat cement 2 Cement grout 3 Bentonite 4 Other \_\_\_\_\_  
Grouted Intervals: From 0 ft. to 10 ft., From \_\_\_\_\_ ft. to \_\_\_\_\_ ft. to \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
What is the nearest source of possible contamination:  
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well  
2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well  
3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below) NONE  
Direction from well \_\_\_\_\_ How many feet \_\_\_\_\_ ? Water Well Disinfected? Yes  No \_\_\_\_\_  
Was a chemical/bacteriological sample submitted to Department? Yes \_\_\_\_\_ No  If yes, date sample submitted \_\_\_\_\_ month \_\_\_\_\_ day \_\_\_\_\_ year: Pump Installed? Yes  No \_\_\_\_\_  
If Yes: Pump Manufacturer's name F & W Model No. 5BK5 HP 1/2 Volts 230  
Depth of Pump Intake 77 ft. Pumps Capacity rated at 15 gal./min.  
Type of pump: 3 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other \_\_\_\_\_

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on May month 3 day 1980 year  
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 199  
This Water Well Record was completed on July month 15 day 1980 year under the business name of Karst Water Well Service by (signature) M.B. Karst

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
	0	3	Topsoil			
	3	40	Clay			
	40	58	Clay and sand mixed			
	58	75	Medium gravel			
	75	80	Blue shale			

ELEVATION: Upland

Depth(s) Groundwater Encountered 1. \_\_\_\_\_ ft. 2. \_\_\_\_\_ ft. 3. \_\_\_\_\_ ft. 4. \_\_\_\_\_ ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY  
1/3  
1/8  
EWD  
SEC.  
2/8  
SE 1/4  
NW 1/4  
SW 1/4  
SE 1/4