

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ellis	Fraction SE 1/4 SW 1/4 SE 1/4	Section number 28	Township number T 13 S R 18	Range number 18	E/W (18)
2. Distance and direction from nearest town or city: Street address of well location if in city: 2928 Willow Hays, Ks				3. Owner of well: Flowers by Frances R.R. or street: 420 E Eighth Hays, Ks. City, state, zip code:			
4. Locate with "X" in section below:		Sketch map: Willow			6. Bore hole dia. 9 in. Completion date 5-19-79 Well depth 62 ft.		
		<p>house</p> <p>30th</p> <p>well</p>			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
					9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 62 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .26		
					10. Screen: Manufacturer's name jet stream Type pvc Dia. 5 Slot/gauge .031 Length 10 Set between 50 ft. and 60 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/2		
					11. Static water level: 48 ft. below land surface Date 5-19-79 mo./day/yr.		
					12. Pumping level below land surfaces: 50 ft. after 1 hrs. pumping 15 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 15 g.p.m.		
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
					14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter		
					15. Well grouted? <input checked="" type="checkbox"/> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 12 ft.		
					16. Nearest source of possible contamination none ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
					17. Pump: F&W <input type="checkbox"/> Not installed Manufacturer's name Model number 5ba8 HP 1/2 Volts 220 Length of drop pipe 56 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Well 199 Business name E. Hiway 40 Hays, Ks. License No. Address Mel Karst Date 5-19-79 Signed Mel Karst Authorized representative		
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

T 13
 R 18
 E (18)
 Sec 28
 SE 1/4 SW 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5