

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

1318W28SESE
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County ELLIS	Township name Big creek	Fraction SE 1/4 SE 1/4	Section number 28	Town number 13 W	Range number 18 S
Distance and direction from nearest town or city: Street address of well location if in city: 2708 Woodrow cl				3 Owner of well: Marvin W. Glotzbeck Address: 2708 Woodrow cl Hays, Kansas 67601		
Locate with "X" in section below: N W E S 1 Mile		Sketch map: located in city of Hays		4 Well depth: 65 ft. Date of completion: 8/11/25 Well diameter 6 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
From To Silt, tan, with Caliche nodules 0 54 Sand, poorly sorted, with some 1/2" limy gravel, 54 65 and a small amount of quartz gravel. Saturated below 54.5 feet. Silty clay on bottom - quit 65 because water supply thought adequate hole drilled with hand auger from 0 to 54 feet, then casing set & bailed down to 65 feet.				7 Casing: Material Plastic height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 20 in. Diam. 5 in. to 65 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 4 1/2 lbs./ft.		
				8 Screen: Manufacturer _____ Type Plastic Dia. 5" Slot/gauze 3/32" Length 20' Set between 54.5 ft. and 65 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2"		
				9 Static water level: 55 ft. below land surface Date 8/11/25		
				10 Pumping level below land surfaces: 55 ft. after 12 hrs. pumping 7 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter 20 inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> SOIL Depth: From 55 ft. to Surface		
				14 Nearest source of possible contamination: ft. 10 Direction North Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Sears Model number _____ HP 1/2 Volts 220 Length of drop pipe 60 ft. capacity 7 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Individual Business name _____ License No. _____ Address _____ Signed Marvin W. Glotzbeck Date 8/11/25 Authorized representative		