

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ellis	Fraction SW 1/4 SW 1/4 ONE 1/4	Section number 28	Township number T 13 S R 18 E	Range number 18
2. Distance and direction from nearest town or city: Street address of well location if in city: Hays Jr. High			3. Owner of well: U.S. D 489 R.R. or street: 230 West 11th City, state, zip code: Hays, Kansas 67601			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 9/4/75 Well depth 56 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Topsoil		0	6	X Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 5 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258		
Yellow Subsoil		6	15	10. Screen: Manufacturer's name Jet Stream Type PVC Dia. 5" Slot/gauge <input checked="" type="checkbox"/> Length 10' Set between 45 ft. and 55 ft. ft. and <input type="checkbox"/> ft.		
Brown Clay		15	41	Gravel pack? Yes Size range of material 1/4-1/2		
Silty Sand		41	46	11. Static water level: <input type="checkbox"/> mo./day/yr. 43 ft. below land surface Date 9/4/75		
Fine - Medium Sand		46	53	12. Pumping level below land surfaces: 48 ft. after 1 hrs. pumping 25 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 25 g.p.m.		
Blue Shale		53	56	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 16 inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 1 ft. to 11 ft.		
				16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Few Model number CH27 HP 1 1/2 Volts 220 Length of drop pipe 32 ft. capacity 27 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: flat		(Use a second sheet if needed)		20. Water well contractor's certification: <input checked="" type="checkbox"/> This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harst Water Well 199A Business name E Hwy 40 Hays License No. <input type="checkbox"/> Address M.D. Harst Date 9/4/75 Signed M.D. Harst Authorized representative		
19. Remarks: None						

T 13 S 18 E Sec 28 SW 1/4 SW 1/4