


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Ellis</b>	Township name <b>Big Creek</b>	Fraction <b>SE 1/4</b>	Section number <b>29</b>	Town number <b>13</b>	Range number <b>18 N</b>		
Distance and direction from nearest town or city: Street address of well location if in city: <b>1108 Oakmont Lt Hays, Kansas</b>			3 Owner of well: <b>Jack Kristie</b> Address: <b>1108 Oakmont Lt. Hays, Kansas</b>					
Locate with "X" in section below: N  W E S 1 Mile			4 Well depth: <b>90</b> ft. Date of completion <b>10-21-75</b> Well diameter <b>10</b> in.			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> <b>House</b>					
2			Type and color of material			7 Casing: Material <b>Plt</b> Height: <b>above</b> below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>18</b> in. Diam. <b>5</b> in. to <b>6 1/2</b> ft. depth Weight <b>glue</b> lbs./ft. <b>---</b> <b>---</b> in. to <b>---</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No <b>200-1-35-1/4" Hall</b>		
			From To			8 Screen: Manufacturer <b>Best + Lowell</b> Type <b>PDS</b> Dia. <b>5</b> Slot/gauze <b>1/16</b> Length <b>36</b> Set between <b>6 1/2</b> ft. and <b>90</b> ft. Fittings: <b>1 1/2 - 1 1/4</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>---</b>		
Topsoil			0			9 Static water level: <b>57</b> ft. below land surface Date <b>10-21-75</b>		
Clay silty brown			8			10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <b>12</b> g.p.m.		
Clay, Sand v fine grayish Brown			54			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
Sand v-fine to coarse red			64			12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <b>18</b> Inches above grade		
Shale compact Blue to gray Black			89			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ____ Depth: From <b>6</b> ft. to <b>20</b> ft.		
						14 Nearest source of possible contamination: ft. <b>15</b> Direction <b>NE</b> Type <b>sewer line</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief, <b>Luna Water Well Drilling</b> Business name License No. <b>276</b> Address <b>503 Inwood</b> Signed <b>John Kula</b> Date <b>10-21-75</b> Authorized representative		

13 18 W 29 NE SE SE

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Farm WWC-5