

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ellis	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 34	Township number T 13 S R 18 E W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 2510 Gen. Lawton Hays, Ks.			3. Owner of well: Ernie Klaus R.R. or street: 2510 Gen. Lawton City, state, zip code: Hays, Ks.		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: Gen. Lawton		
			6. Bore hole dia. 9 in. Completion date 8-8-79 Well depth 47 ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material			9. Casing: Material pvc Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 47 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .26		
			10. Screen: Manufacturer's name Jrt stream Type pvc Dia. 5 Slot/size .031 Length 10 Set between 37 ft. and 47 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 - 3/4		
topsoil			From 0 To 4		
clay			From 4 To 26		
medium sand			From 26 To 43		
blue shale			From 43 To 47		
			11. Static water level: 30 ft. below land surface Date 8-8-79 mo./day/yr.		
			12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 12 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 12 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: 16 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 12 ft.		
			16. Nearest source of possible contamination: none ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Pumpco Model number UK HP 1/2 Volts 220 Length of drop pipe 47 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Well 199 Business name E. Hiway 40 Hays license No. Address Hays Sign E. Hiway Date 8-8-79 Authorized representative			

T 13 S R 18 E W
 Sec 34
 NW 1/4 SE NW
 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5