

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County ELLIS	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 34	Township number T 13 S R 18	Range number 18
2. Distance and direction from nearest town or city: Street address of well location if in city: 1010 DOWNING HAYS			3. Owner of well: Centennial Towers Assoc. R.R. or street: 1010 Downing Ave. City, state, zip code: HAYS, KS. 67601		
4. Locate with "X" in section below: Sketch map: o-well			6. Bore hole dia. 9 in. Completion date 4/15/77 Well depth 63 ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 14 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 43 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 160 P31		
			10. Screen: Manufacturer's name Jet stream Type PVC Dia. 5" Slot/gauze .031 Length 10' Set between 53 ft. and 63 ft. Gravel pack? yes Size range of material 1/4-1/8		
			11. Static water level: _____ mo./day/yr. 42 ft. below land surface Date 4/15/77		
			12. Pumping level below land surfaces: 45 ft. after 1 hrs. pumping 60 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 60 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 13 ft.		
			16. Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? yes Yes _____ No		
			17. Pump: _____ Not installed Manufacturer's name FWD Model number _____ HP 5 Volts 230 Length of drop pipe 50 ft. capacity 60 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. KANSAS WATER WELL CONTRACTORS Business name _____ License No. _____ Address Hilary 40 Hays Signed [Signature] Date 4/15/77 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5