


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Ellis	Township name	Fraction NW 1/4 SW 1/4 SE 1/4	Section number 34	Town number 18	Range number 18
Distance and direction from nearest town or city: Street address of well location if in city: 1324 Douglas Dr.				3 Owner of well: Duane Klein Address: 1324 Douglas Dr. Hays, Kans.		
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		4 Well depth: 42 ft. Date of completion 4/30/75 Well diameter 5 in.	
2 Type and color of material			From To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
Yellow Clay			1 18		7 Casing: Material PVC Height: <u>above</u> /below	
					Threading: <input type="checkbox"/> Bonded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>16</u> in. Diam. <u>2</u> in. to <u>42</u> ft. depth; Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>1</u> in. to <u> </u> ft. depth!	
Sand and Gravel			19 21		8 Screen: Manufacturer Jess Lowell	
					Type Styrene Dia. 5" Slot/gauze Slot Length 10" Set between 32 ft. and 42 ft. Fittings: Collars Gravel pack <input type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u> </u>	
Yellow Clay			22 37		9 Static water level: 30 ft. below land surface Date 4/30/75	
					10 Pumping level below land surfaces: 34 ft. after 1 hrs. pumping 20 g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield 25 g.p.m.	
Gravel			38 41		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
Shale			41 42		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 1 ft. to 10 ft.	
					14 Nearest source of possible contamination: ft. None Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
(use a second sheet if needed)					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					16 Remarks: elevation Upland Slopping Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Water Well Sales Business name <u> </u> License No. <u> </u> Address East 8th Hays, Kans Signed <u> </u> Date <u> </u> Authorized representative	

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5