

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Ellis		X Fraction NW 1/4 NE 1/4 NE 1/4		Section number 34	Township number T 13 S R 18 E W	Range number 18 E W
2. Distance and direction from nearest town or city: Street address of well location if in city: 22nd & Henry				3. Owner of well: Gary Rohr R.R. or street: Henry Drive City, state, zip code: Hays, Kansas 67601		
X Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 9/2/75 Well depth 65 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Topsoil				0	4	X Casing: Material PVC Height: <input checked="" type="checkbox"/> Above <input type="checkbox"/> below
Yellow Subsoil				4	15	Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in.
Brown Clay				15	40	RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft.
Brown Clay & Fine Sand				40	51	Dia. 5 in. to 65 ft. depth Wall Thickness: inches or
Medium Sand				51	61	Dia. _____ in. to _____ ft. depth gage No. 2258
Blue Shale				61	65	10. Screen: Manufacturer's name Jet Stream
						Type PVC Dia. 3.5"
						Slot/ gauze _____ Length 10'
						Set between 55 ft. and 65 ft.
						_____ ft. and _____ ft.
						Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/4-1/2
						11. Static water level: _____ mo./day/yr. 40 ft. below land surface Date 9/2/75
						12. Pumping level below land surfaces: 42 ft. after 1 hrs. pumping 10 g.p.m.
						_____ ft. after _____ hrs. pumping _____ g.p.m.
						Estimated maximum yield 10 g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
						14. Well head completion: _____ Pitless adapter 18 Inches above grade
						X Well grouted? <input checked="" type="checkbox"/> Yes
						With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete
						Depth: From _____ ft. to _____ ft.
						16. Nearest source of possible contamination: None
						ft. _____ Direction _____ Type _____
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed
						Manufacturer's name _____
						Model number _____ HP _____ Volts _____
						Length of drop pipe _____ ft. capacity _____ g.p.m.
						Type:
						<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine
						<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating
						<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		None				
		X Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst water Well 199A Business name _____ License No. _____ Address E Hwy 40 Hays Signed [Signature] Date 9/2/75 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5