


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Ellis	Township name	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 34	Town number 13	Range number 18
Distance and direction from nearest town or city:				3 Owner of well: Edward J. Stremel		
Street address of well location if in city: 1510 Haney Dr. Hays, Kans.				Address: 1510 Haney Dr. Hays, Kans.		
Locate with "X" in section below: N  Sketch map:				4 Well depth: 37 ft. Date of completion 4/12/75 Well diameter 5 in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. Bonded Weight 160 lbs./ft. 1 5 in. to 37 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth		
2 Type and color of material		From	To	8 Screen: Manufacturer Jess Lowell Type Styrene Dia. 5" Slot/gauze Slot Length 10' Set between 37 ft. and 27 ft. Fittings: Collars Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material —		
Fine sand and clay		1	22			
Clay yellow		23	27			
Sand		27	36			
Shale		36	37			
				9 Static water level: 27 ft. below land surface Date 4/12/75		
				10 Pumping level below land surfaces: 31 ft. after 1 hrs. pumping 25 g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 30 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 1 ft. to 10 ft.		
				14 Nearest source of possible contamination: ft. None Direction — Type — Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name — Model number — HP — Volts — Length of drop pipe — ft. capacity — g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation Level		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Water Well Sales Business name License No. — Address East 8th Hays, Kans. Signed — Date — Authorized representative				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5