

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ellis	Fraction SE 1/4 NE 1/4 SW 1/4	Section number 34	Township number T # 13 S R 18 E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 1903 Mac Arthur			3. Owner of well: Albert Hamel Jr. R.R. or street: 1903 MacArthur City, state, zip code: Hays, Ks. 67601		
4. Locate with "X" in section below: N W S E 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. <u>6</u> in. Completion date <u>4-10-76</u> Well depth <u>55</u> ft.
Topsoil			0	7	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input checked="" type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay			7	19	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine Rock			19	24	9. Casing: Material <u>plst</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>gl</u> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.
Dry Sand			24	43	Dia. <u>5</u> in. to <u>55</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <u>200</u>
Water Sand			43	55	10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5 in</u> Slot/gauze <u>26</u> Length <u>6 ft.</u> Set between <u>49</u> ft. and <u>55</u> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.
Blue Shale			55		Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/2</u>
					11. Static water level: <input type="checkbox"/> mo./day/yr. <u>45</u> ft. below land surface Date <u>4-9-76</u>
					12. Pumping level below land surfaces: <u>45</u> ft. after <u>1</u> hrs. pumping <u>12</u> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>700 gph</u> g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>12</u> ft. to <u>0</u> ft.
					16. Nearest source of possible contamination: <u>Sewer</u> ft. <u>31</u> Direction <u>N</u> Type <u>LINE</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Fairbanks Morse</u> Model number <input type="checkbox"/> HP <u>1/2</u> Volts <u>220</u> Length of drop pipe <u>53</u> ft. capacity <u>15</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>R. F. Coupal</u> <u>266</u> Business name License No. Address <u>616 E. 6th Hays, Ks</u> Signed <u>Raymond F. Coupal</u> Date <u>4-10-76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 13 R 18 E/W S 34 SE NE SW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5