

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Ellis	Township name	Fraction NW¹/₄ SE¹/₄ NE¹/₄	Section number 34	Town number 13	Range number 18 W	
Distance and direction from nearest town or city: Street address of well location if in city: 1511 Haney			3 Owner of well: Alvin J. Riedel Address: 1511 Haney Dr. Hays, Ks 67601				
Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		4 Well depth: 43 ft. Date of completion 9-10-74 Well diameter 6 in.		
2 Type and color of material			From To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Lawn		
Topsoil BLACK			0 5		7 Casing: Material Plst Height: above/below Threaded <input type="checkbox"/> gW Welded <input type="checkbox"/> Surface 12 in. Diam. _____ Weight _____ lbs./ft. _____ 5 in. to 43 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No _____ in. to _____ ft. depth: 0.258 gage		
Clay, sandy, grayish brown			5- 23		8 Screen: Manufacturer Jess & Lovell Type RMP Dia. 5" Slot gauze 0.06(1/16) length 10 Set between 33 ft. and 43 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2		
Sand, v.fine, brown			23 28		9 Static water level: 29 ft. below land surface Date 9-9-74		
Sand, coarse, brown			28 43		10 Pumping level below land surfaces: 37 ft. after 1 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 23 g.p.m.		
Blue Shale			43		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 2 inches above grade		
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From Sur ft. to 10 ft.		
					14 Nearest source of possible contamination: ft. 20 Direction N Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)							
16 Remarks: elevation Topography: Level <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. R. F. Coupal 266 Business name License No. Address 616 E. 6th Hays, Ks. Signed Raymond Coupal Date 9-10-74 Authorized representative		

13 1800 34 NW SE NE