

County: Ellis Fraction N2 SW SE Sec. 32 T 13 S R 18 E (W)

CORRECTION(S) TO WATER WELL COMPLETION RECORD (WWC-5)

(to rectify lacking or incorrect information)

Owner: Ft. Hays State College

Location was listed as:

Section-Township-Range: 4-14S-18W

Fraction ($\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$): NW $\frac{1}{4}$

Location changed to:

32-13S-18W

N2 SW SE

Other changes: Initial statements: _____

Changed to: _____

Comments: _____

Verification method: Attached well location map, and mapping tool & aerial photos on KGS website.

initials: DRL date: 9/18/2015

Submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726


to: Kansas Dept of Health & Environment, Bureau of Water, 1000 SW Jackson, Suite 420, Topeka, KS 66612-1367.

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

| | | | | | | |
|---|---------------------|---------------|--|-------------------------|---|--|
| 1 Location of well: | County Ellis | Township name | Fraction NW 1/4 | Section number 4 | Town number T145 | Range number R18W |
| Distance and direction from nearest town or city: Near President's Residence on Campus | | | 3 Owner of well: Ft. Hays State College Address: Hays, Kansas | | | |
| Locate with "X" in section below:  | | | Sketch map: See Attached Map | | | 4 Well depth: 49.15 ft. Date of completion 3/6/75 Well diameter 30 in. |
| 2 Type and color of material | | | From | To | 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary | |
| Top soil | | | 0 | 5 | 6 Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well | |
| Brown clay with some sand | | | 5 | 10 | 7 Casing: Material <u>STL</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 30 in. Diam. _____ Weight 35 lbs./ft. 10 in. to 39 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth | |
| Brown clay with med. sand & gravel | | | 10 | 25 | 8 Screen: Manufacturer <u>Layne</u> Type <u>Stn stl</u> Dio. <u>10"</u> Slot/gauge <u>5</u> Length <u>10'</u> Set between <u>39</u> ft. and <u>49</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>3/16 x 3/8</u> | |
| Gray clay with med. sand & gravel | | | 25 | 40 | 9 Static water level: 17.45 ft. below land surface Date 3/6/75 | |
| Med. to coarse sand & gravel | | | 40 | 47 | 10 Pumping level below land surfaces: 25 ft. after 2 hrs. pumping 150 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 200 g.p.m. | |
| Blue shale | | | 47 | 48 | 11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ | |
| | | | | | 12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade 30 | |
| | | | | | 13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <u>0</u> ft. to <u>20</u> ft. | |
| | | | | | 14 Nearest source of possible contamination: ft. <u>100</u> Direction <u>North</u> Type <u>Sewer</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| | | | | | 15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Layne</u> Model number <u>77671</u> HP <u>7 1/2</u> Volts <u>208</u> Length of drop pipe <u>40</u> ft. capacity <u>100</u> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | |
| 16 Remarks: elevation | | | 17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name License No. Address 1011 W. Harry, Wichita, Ks Signed _____ Date 3/25/75 | | | |
| Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley | | | | | | |

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

