


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction NW SE SE SE 1/4 SE 1/4 SW 1/4	Section number 5 5	Township number T 13	Range number S R 2W	E/W
2. Distance and direction from nearest town or city: 6 mi. N + 2.5 E. Salina Street address of well location if in city: (2.5 E)				3. Owner of well: Randy Crough R.R. or street: 511 Aullwood City, state, zip code: Salina Ks. 67401			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 in. Completion date 11-10-77 Well depth 56 ft.			
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		In feet below surface:		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 4 in. to 56 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 5.40			
Colluvium		From 0 To 5		10. Screen: Manufacturer's name Shop			
Silt, sandy, brown				Type slots Dia. 4"			
Kiowa fm:				Slot/gauze 1/16" Length 5'			
Sandstone, fine to medium		5 56		Set between 51 ft. and 56 ft. ft. and ft.			
Shale, dark gray		56 57		Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/10"			
				11. Static water level: <input type="checkbox"/> mo./day/yr. 40 ft. below land surface Date 11-10-77			
				12. Pumping level below land surfaces: 45 ft. after 42 hrs. pumping 4 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 6 g.p.m.			
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date			
				14. Well head completion: Pitless adapter 12 inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.			
				16. Nearest source of possible contamination: Open ft. Direction Type field Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hyphonic Drilling 126 Business name Salina Ks License No. Address Ad Fest 12-5-77 Signed Ad Fest Date 12-5-77 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5