

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

NE NW NW

1 Location of well:	County Ellis	Township name Pleasant Hill	Fraction NE NW NW	Section number 26	Town number 13	Range number 20				
Distance and direction from nearest town or city:				3 Owner of well: Don Younger						
Street address of well location if in city:				Address: RR#2 Ellis, Kansas						
Locate with "X" in section below:		Sketch map:		4 Well depth: 69 ft. Date of completion 7-8-75 Well diameter 7 in.						
N W ——— E S 1 Mile				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary						
2		Type and color of material		From		To		6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Test well <input type="checkbox"/>		
								7 Casing: Material Plastic Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. collar + screws Weight _____ lbs./ft. 5 _____ in. to _____ ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No 5 in. to 49 ft. depth 200-8-35-1/4" thick		
		Black dirt with Jumbo		0		9		8 Screen: Manufacturer Jess & Howell Type Plastic Dia. 5 Slot gauge _____ Length 20 Set between 49 ft. and 69 ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material _____		
		White rock + yellow Rock		9		68		9 Static water level: 55 ft. below land surface Date 7-8-75		
		Shale		68		69		10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15 g.p.m.		
								11 Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 7-14-75		
								12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
								13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 4 ft. to 14 ft.		
								14 Nearest source of possible contamination: ft. 100 Direction S-W Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
								15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Fairbank Morse Model number _____ HP 1 Volts 220 Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation								17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Luce Water Well Drilling Business name _____ License No. _____ Address 503 Monroe _____ Signed John Luce _____ Date 7-8-75 Authorized representative Ellis, Kansas		
		Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley								

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5