


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Stewarts

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County Trego		Section NW 1/4 SE 1/4 NW 1/4	Section number 26	Township number T 13 S R 25 E 10	Range number 25
2. Distance and direction from nearest town or city: 105 - 3 E		3. Owner of well: Castle Rock Ranch			
Street address of well location if in city: of Colyer		R.R. or street: Quinter, Ks. 67752			
City, state, zip code:					
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 19 in. Completion date _____ Well depth 89 ft. 1/3/77	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height 12 ft. below Threaded _____ Welded _____ Surface _____ in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 12 in. to 89 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 3/4 12	
5. Type and color of material		From	To	10. Screen: Manufacturer's name _____ Johnson Well Casing Type cement asbestos 12 in. Slot/gauze 3/4 Length 30 ft. Set between 50 ft. and 89 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4	
				11. Static water level: _____ no./day/yr. 40 ft. below land surface Date 1/3/77	
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 400 g.p.m.	
				13. Water sample submitted: _____ no./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
				14. Well head completion: _____ Piles adapter _____ inches above grade <input checked="" type="checkbox"/> Well grouted? concrete slab With: _____ Neat cement _____ Bentonite _____ Concrete Depth: From 0 ft. to 2 ft.	
				15. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Agua Well Drilling 281 Business name _____ License No. _____ Address Gove, Ks. 67736 Signed J. M. Jettie Date 1/3/77		
Topography: Hill _____ Slope _____ Canyon _____ Valley _____					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5