

LOCATION OF WATER WELL	Fraction	Section Number	Township Number	Range Number
County: <u>Salina</u>	NW 1/4 NE 1/4 NE 1/4	2	T 13 S	R 3 E/W

Distance and direction from nearest town or city? North 8 miles

Street address of well if located within city?

WATER WELL OWNER: Howard Kreitzer

Rt. #, St. Address, Box #: Rt. 2 Box 373

City, State, ZIP Code: Salina, Ks. 67401

Board of Agriculture, Division of Water Resources
Application Number:

DEPTH OF COMPLETED WELL: 77 ft. Bore Hole Diameter: 9 in. to ... ft., and ... in. to ... ft.

Well Water to be used as:

<input checked="" type="checkbox"/> Domestic	<input type="checkbox"/> Public water supply	<input type="checkbox"/> Air conditioning	<input type="checkbox"/> Injection well
<input type="checkbox"/> 3 Feedlot	<input type="checkbox"/> Oil field water supply	<input type="checkbox"/> Dewatering	<input type="checkbox"/> 12 Other (Specify below)
<input type="checkbox"/> 2 Irrigation	<input type="checkbox"/> Lawn and garden only	<input type="checkbox"/> 10 Observation well	

Well's static water level: 15 ft. below land surface measured on 4 month 2 day 82 year

Jump Test Data: Well water was 35 ft. after 40 hours pumping 15 gpm

St. Yield 40 gpm: Well water was ... ft. after ... hours pumping ... gpm

TYPE OF BLANK CASING USED:

<input checked="" type="checkbox"/> 1 Steel	<input type="checkbox"/> 5 Wrought iron	<input type="checkbox"/> 8 Concrete tile	Casing Joints: <input checked="" type="checkbox"/> Glued <input type="checkbox"/> Clamped
<input type="checkbox"/> 2 Brass	<input type="checkbox"/> 6 Asbestos-Cement	<input type="checkbox"/> 9 Other (specify below)	<input type="checkbox"/> Welded
<input checked="" type="checkbox"/> 3 PVC	<input type="checkbox"/> 7 Fiberglass		<input type="checkbox"/> Threaded

Blank casing dia: 5 in. to 48 ft., Dia 95 in. to ... ft., Dia ... in. to ... ft.

Casing height above land surface: 12 in., weight 160 lbs./ft. Wall thickness or gauge No SDR 26

TYPE OF SCREEN OR PERFORATION MATERIAL:

<input checked="" type="checkbox"/> 1 Steel	<input type="checkbox"/> 3 Stainless steel	<input type="checkbox"/> 5 Fiberglass	<input type="checkbox"/> 8 RMP (SR)	<input type="checkbox"/> 10 Asbestos-cement	<input type="checkbox"/> 11 Other (specify)
<input type="checkbox"/> 2 Brass	<input type="checkbox"/> 4 Galvanized steel	<input type="checkbox"/> 6 Concrete tile	<input type="checkbox"/> 9 ABS	<input type="checkbox"/> 12 None used (open hole)	

Screen or Perforation Openings Are:

<input type="checkbox"/> 1 Continuous slot	<input type="checkbox"/> 3 Mill slot	<input type="checkbox"/> 5 Gauzed wrapped	<input checked="" type="checkbox"/> 8 Saw cut	<input type="checkbox"/> 11 None (open hole)
<input type="checkbox"/> 2 Louvered shutter	<input type="checkbox"/> 4 Key punched	<input type="checkbox"/> 6 Wire wrapped	<input type="checkbox"/> 9 Drilled holes	
		<input type="checkbox"/> 7 Torch cut	<input type="checkbox"/> 10 Other (specify)	

Screen-Perforation Dia: 5 in. to 30 ft., Dia ... in. to ... ft., Dia ... in. to ... ft.

Screen-Perforated Intervals: From 15 ft. to 35 ft., From 67 ft. to 77 ft.

Gravel Pack Intervals: From 10 ft. to 77 ft., From ... ft. to ... ft.

GROUT MATERIAL:

<input type="checkbox"/> 1 Neat cement	<input type="checkbox"/> 2 Cement grout	<input checked="" type="checkbox"/> 3 Bentonite	<input type="checkbox"/> 4 Other
--	---	---	----------------------------------

Grouted Intervals: From 1 ft. to 10 ft., From ... ft. to ... ft., From ... ft. to ... ft.

What is the nearest source of possible contamination:

<input checked="" type="checkbox"/> 1 Septic tank	<input type="checkbox"/> 4 Cess pool	<input type="checkbox"/> 7 Sewage lagoon	<input type="checkbox"/> 10 Fuel storage	<input type="checkbox"/> 14 Abandoned water well
<input type="checkbox"/> 2 Sewer lines	<input type="checkbox"/> 5 Seepage pit	<input type="checkbox"/> 8 Feed yard	<input type="checkbox"/> 11 Fertilizer storage	<input type="checkbox"/> 15 Oil well/Gas well
<input type="checkbox"/> 3 Lateral lines	<input type="checkbox"/> 6 Pit privy	<input type="checkbox"/> 9 Livestock pens	<input type="checkbox"/> 12 Insecticide storage	<input type="checkbox"/> 16 Other (specify below)
			<input type="checkbox"/> 13 Watertight sewer lines	

Direction from well: West How many feet: 75 ? Water Well Disinfected? Yes No

Has a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample submitted ... month ... day ... year

Pump Installed? Yes No

Yes: Pump Manufacturer's name: Webtrol Model No. 102 S58B HP 1/2 Volts 230

Depth of Pump Intake ... ft. Pumps Capacity rated at 10 gal./min.

Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 4 month 2 day 82 year

and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 388

This Water Well Record was completed on 4 month 6 day 82 year under the business name of Pestinger Pump Ser. by (signature) Paul J. Pestinger

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		1	13	Top Soil		
	14	42	Sand Stone			
	43	66	Clay			
	67	77	Shale			

ELEVATION: Depth(s) Groundwater Encountered 1. 19 ft. 2. 67 ft. 3. ... ft. 4. ... ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.