

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction Lot 12 N 1/2 1/4 NW 1/4 NW/4	Section number 19	Township number T 13	Range number S R 3W E/W
2. Distance and direction from nearest town or city: 2 mi N + 4W			3. Owner of well: Gus Reed			
Street address of well location if in city: Salina Kans			R.R. or street: 421 N. Ohio			
			City, state, zip code: Salina Kans 67401			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 in. Completion date _____ Well depth 85 ft. 9-15-77		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From		To		9. Casing: Material _____ Height: <u>Above</u> or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 85 ft. depth Wall thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 5 40
						10. Screen: Manufacturer's name Shop Type slots Dia. 4" Slot/gauze _____ Length 8' Set between 77 ft. and 85 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8"
Clay, silty, tan		0		4		11. Static water level: _____ mo./day/yr. 44 ft. below land surface Date 6-30-77
Shale, yellow + gray; contains some interbedded sandstone		4		78		12. Pumping level below land surfaces: ND ft. after 1 hrs. pumping 8 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.
Sandstone, fine to medium		78		85		13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Shale, dark gray + siltstone		85		135		14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.
						16. Nearest source of possible contamination: fr. Open field _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydronics Drilling 126 Business name _____ License No. _____ Address Salina, Kans. Signed Paul Faust Date 9-29-77 Authorized representative
18. Elevation:		19. Remarks: 				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

13 30 19 NW/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5