

LOCATION OF WATER WELL
 County: Saline Fraction: SW 1/4 NE 1/4 SW 1/4 Section Number: 36 Township Number: T 13 S Range Number: R 3W E/W

Distance and direction from nearest town or city? 1/2 Mi. N. Salina Street address of well if located within city?

WATER WELL OWNER: Ted Harder
 R#, St. Address, Box #: PO Box 1661 Board of Agriculture, Division of Water Resources
 City, State, ZIP Code: Salina Kans 67401 Application Number:

DEPTH OF COMPLETED WELL: 49.5 ft. Bore Hole Diameter: 6 in. to 49.5 ft. and in. to ft.

Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 7 Lawn and garden only 10 Observation well

Well's static water level: 22 ft. below land surface measured on Dec. month 23 day 1980 year
 Pump Test Data: Well water was ND ft. after 1/2 hours pumping 30 gpm
 Static Yield 30 gpm: Well water was ft. after hours pumping gpm

TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
 7 Fiberglass Threaded

Blank casing dia: 4 in. to 46.5 ft., Dia in. to ft., Dia in. to ft.
 Casing height above land surface: 12 in., weight lbs./ft. Wall thickness or gauge No SDR 26

TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify)
 9 ABS 12 None used (open hole)

Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify)

Screen-Perforation Dia: 4 in. to 49.5 ft., Dia in. to ft., Dia in. to ft.
 Screen-Perforated Intervals: From 46.5 ft. to 49.5 ft., From ft. to ft.
 Gravel Pack Intervals: From 36 ft. to 49.5 ft., From ft. to ft.

GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From 3 ft. to 13 ft., From ft. to ft., From ft. to ft.

What is the nearest source of possible contamination: Open field
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
 13 Watertight sewer lines

Direction from well How many feet ? Water Well Disinfected? Yes No
 Has a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample
 as submitted month day year: Pump Installed? Yes No
 Yes: Pump Manufacturer's name Model No. HP Volts
 Depth of Pump Intake ft. Pumps Capacity rated at gal./min.

TYPE OF PUMP: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other
 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was
 completed on Dec. month 23 day 1980 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 126
 This Water Well Record was completed on Jan. month 14 day 1981 year under the business
 name of Hydraulic Drilling Co by (signature) O. J. Faust

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
	0	30	Clay, tan			
	30	36	Silt, sandy, tan			
	36	42	Sand & gravel, silty			
	42	49.5	Gravel, fine to coarse			
ELEVATION:						

Depth(s) Groundwater Encountered 1. 36 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.