

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WESKAN

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Job #158-77-C-33-13-41

CDD

1. Location of well:	County Wallace	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 33	Township number T 13 S	Range number R 41 E/W
----------------------	--------------------------	---	-----------------------------	----------------------------------	---------------------------------

2. Distance and direction from nearest town or city: 7 1/2 W; 2 S; 1/2 E. Street address of well location if in city:	3. Owner of well: John Ostmeyer R.R. or street: City, state, zip code: Colby, Kansas
--	--

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. **30** in. Completion date **4-28-77**
Well depth **225** ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material **Steel** Height: Above ~~0~~ **12** in.
Threaded Welded Surface **12** in.
RMP PVC Weight **.188** lbs./ft.
Dia. **16** in. to **155** ft. depth Wall Thickness **1/8** inches or
Dia. in. to ft. depth gage No. **177**

5. Type and color of material	From	To
Clay	0	125
Coarse Sand, Gravel	125	135
Clay	135	144
Coarse Sand, Coarse Gravel	144	160
Coarse Sand, Gravel	160	195
Clay	195	201
Coarse Sand, Med. Gravel	201	206
Coarse Sand, Gravel, Clay	206	212
Coarse Sand, Gravel	212	216
Clay	216	218
Coarse Sand, Gravel	218	225
BROCK ?		

10. Screen: Manufacturer's name
W. A. Brown
Type **Bridge** Dia. **16"**
Slot/gauze **10%** Length **60'**
Set between **155** ft. and **215** ft.
10' Cook 215 ft. and **225** ft.
Gravel pack? Size range of material **1/4 x 5/8**

11. Static water level: **95** ft. below land surface Date **5-10-77** mo./day/yr.

12. Pumping level below land surfaces:
135 ft. after **2** hrs. pumping **2680** g.p.m.
ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield **2680** g.p.m.

13. Water sample submitted: _____ mo./day/yr.
Yes No Date _____

14. Well head completion:
 Pitless adapter **12** inches above grade

15. Well grouted?
With: Neat cement Bentonite Concrete
Depth: From **0** ft. to **10** ft.

16. Nearest source of possible contamination: **** ->**
ft. _____ Direction _____ Type _____
Well disinfected upon completion? _____ Yes _____ No

17. Pump: Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation:	19. Remarks: 3785 (TOPO)	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address Box 852, Colby, KS 67701 Signed Dally Berry Date 6/21/77 Authorized representative
----------------	------------------------------------	---

**Nothing within one mile E
 1 3
 4 10
 R
 3 3
 SE SE SW
 1/4 1/4 1/4