

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Saline	Fraction NE 1/4 SE 1/4 SE 1/4	Section number 22	Township number T 13 S R 5W	Range number E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 mi. E. Glendale			3. Owner of well: House, Dick R.R. or street: 2752 Melanie Lane City, state, zip code: Salina Ks 67401			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 in. Completion date Well depth 20 ft. 5-23-77		
		<p style="text-align: center;">FC.</p>		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				From	To	9. Casing: Material _____ Height: <u>Above</u> or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 in. to 20 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. S. 40
Alluvium:						10. Screen: Manufacturer's name Sheep
Clay, silty tan				0	11	Type slots Dia. 4"
Gravel, fine to coarse				11	19	Slot/gauze 1/16" Length 3'
King fm:						Set between 17 ft. and 20 ft. _____ ft. and _____ ft.
Shale, dark gray				19	35'	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/16"
						11. Static water level: _____ mo./day/yr. 13 ft. below land surface Date 5-23-77
						12. Pumping level below land surfaces: 18 ft. after 1/2 hrs. pumping 8 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 8 g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. 300 Direction NW Type stock pens Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydraulic Drilling 126 Business name _____ License No. _____ Address Salina, Ks Signed D.P. Fant Date 7-11-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

T
R
S
E
13 - 50 - 22 NE SE SE
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5