

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County LINCOLN	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 8	Township number T 13 S R 6 E W	Range number
2. Distance and direction from nearest town or city: IN Street address of well location if in city: WESTFALL			3. Owner of well: KEITH SUELTER R.R. or street: City, state, zip code: WESTFALL, KANS			
4. Locate with "X" in section below:		Sketch map: LOT 16 BLOCK 3			6. Bore hole dia. 8 in. Completion date 3/15/79 Well depth 140 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PVC Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1258	
					10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Gauge 1 1/16" Length 20' Set between 120 ft. and 140 ft. Gravel pack? YES Size range of material 4/4	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 70 ft. below land surface Date 3-15-79	
					12. Pumping level below land surfaces: <input type="checkbox"/> ft. after N/A hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 20+ g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
					15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.	
					16. Nearest source of possible contamination: SEPTIC TANK ft. 100 Direction NORTH Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DARYL COX + SONS INC 359 Business name License No. Address WESTFALL KANS 66637 Signed Daryl Cox Date 4-7-79 Authorized representative	
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 13
 R 6
 E W
 S
 Sec 8
 1/4 SE 1/4 SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5