


1 LOCATION OF WATER WELL: County: Russell Fraction: NW 1/4 NW 1/4 SW 1/4 Section Number: 24 Township Number: T 14 S Range Number: R 11 E/W

Distance and direction from nearest town or city street address of well if located within city?
1 W and 1/2 south of Wilson

2 WATER WELL OWNER: Ernest Sebasta
 RR#, St. Address, Box #: Box 13 Board of Agriculture, Division of Water Resources
 City, State, ZIP Code: Wilson, Ks 67490 Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:  4 DEPTH OF COMPLETED WELL: 137 ft. ELEVATION: ft.
 Depth(s) Groundwater Encountered 1. 132 ft. 2. ft. 3. ft.
 WELL'S STATIC WATER LEVEL: 117 ft. below land surface measured on mo/day/yr 6-18-86
 Pump test data: Well water was 115 ft. after 1/2 hours pumping 14 gpm
 Est. Yield 17 gpm: Well water was ft. after hours pumping gpm
 Bore Hole Diameter: 8 in. to 137 ft., and in. to ft.
 WELL WATER TO BE USED AS:
 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well
 Was a chemical/bacteriological sample submitted to Department? Yes..... No ; If yes, mo/day/yr sample was submitted
 Water Well Disinfected? Yes..... No

5 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
 7 Fiberglass Threaded
 Blank casing diameter: 5 in. to 20-127 ft., Dia. in. to ft., Dia. in. to ft.
 Casing height above land surface: 16 in., weight lbs./ft. Wall thickness or gauge No. 2.00
 TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)
 12 None used (open hole)
 SCREEN OR PERFORATION OPENINGS ARE:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify)
 SCREEN-PERFORATED INTERVALS: From 127 ft. to 137 ft., From ft. to ft.
 From ft. to ft., From ft. to ft.
 GRAVEL PACK INTERVALS: From 125 ft. to 137 ft., From ft. to ft.
 From ft. to ft., From ft. to ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Clay Back fill
 Grout intervals: From 125 ft. to 113 ft., From ft. to ft., From 113 ft. to 13 ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well
 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well
 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)
 13 Insecticide storage
 Direction from well? South How many feet? 15-17

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	3	top soil			
3	21	tan clay			
21	79	sand coarse			
79	121	gray shale			
121	131	Brown clay			
131	137	sand fine			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 6-29-86 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. None This Water Well Record was completed on (mo/day/yr) 2-10-87 under the business name of None by (signature) Louis Bushell