

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County ELLIS		Fraction SE 1/4 NW 1/4 NW 1/4	Section number 2	Township number T 14 S	Range number R 18 E W
2. Distance and direction from nearest town or city: Street address of well location if in city: 13th & Canterbury Hays, KS			3. Owner of well: USD 489 R.R. or street: 230 W 11th Hays, KS 67601		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 13th street--- well----- pits----- new high school--		6. Bore hole dia. 9 in. Completion date 5-28-79 Well depth 75 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Topsoil		0	4	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay		4	40	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 75 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200	
yellow clay		40	58	10. Screen; Manufacturer's name Jet Stream	
sand		58	71	Type PVC Dia. 5" Slot gauze 20/30 Length 10' Set between 65 ft. and 75 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4/16	
shale		71	75	11. Static water level: mo./day/yr. 60 ft. below land surface Date 5-28-79	
				12. Pumping level below land surfaces: 65 ft. after 2 hrs. pumping 35 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 35 g.p.m.	
				13. Water sample submitted: mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date	
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 26 ft.	
				16. Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name Flow Model number 5048 HP 1/2 Volts 200 Length of drop pipe 65 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Best water well 199 Business name _____ License No. _____ Address Hays, Ks. Signed [Signature] Date 5-28-79 Authorized representative		

T 14 S
 R 18 E
 W
 Sec 2
 SE NW NW
 1/4 1/4 1/4